Group Home and Child Care Center Fire Safety Checklist Purpose: This checklist is designed to assist child care providers in preparing for their fire safety inspection by listing some of the items to be inspected. This checklist is not all inclusive for fire safety requirements and does not preclude the child care provider from complying with any applicable local fire or building codes. This is not a required form. Yes No N/A Notes Smoke Detectors ☐Yes ☐No ☐N/A Over 49 children require fire alarm system, over 99 children requires fire alarm to be monitored 2A:10BC- 5 lb. Fire Extinguishers ☐Yes ☐No ☐N/A

Fire Doors	☐Yes ☐No ☐N/A	Cannot be propped open. Can be on electromagnetic to fire alarm
Exits	☐Yes ☐No ☐N/A	No interior keyed locks
Exit Signs	☐Yes ☐No ☐N/A	All bulbs working, correct placement, battery backup
Emergency Lighting	☐Yes ☐No ☐N/A	Proper placement
Fire Drill/Date	□Yes □No □N/A	Need to show the date and time of drill, number of children, evacuation time, and number of staff. Less than 3 minutes is considered prompt, greater than 3 minutes but less than 13 minutes is considered slow, and greater than 13 minutes is considered impractical.
Disaster Drill/Date	☐Yes ☐No ☐N/A	One time every 3 months. Need to show the date and time of drill, number of children, evacuation time, and number of staff.
Telephone	☐Yes ☐No ☐N/A	Corded
House Numbers	□Yes □No □N/A	Visible from the street, contrast to bldg.
Fire Alarm System	☐Yes ☐No ☐N/A	Manual pull stations NFPA 72 compliant
Hazardous Material Storage	☐Yes ☐No ☐N/A	No gas, flammable liquid properly stored in 1 hour fire rated room or sprinkled
Interior Finish	☐Yes ☐No ☐N/A	Class C, floor finishes class I or II
Heating System Properly Installed and Maintained	☐Yes ☐No ☐N/A	Correct combustion air, proper venting
Water Heater Properly Installed and Maintained	☐Yes ☐No ☐N/A	T & P valve, Drip leg not plastic
Electric Wiring and Equipment	☐Yes ☐No ☐N/A	NFPA 70
Range Hood System	☐Yes ☐No ☐N/A	Commercial stoves or residential with more than 4 burners
Smoke Barrier-Partitions	☐Yes ☐No ☐N/A	May be required
Furnace Room	☐Yes ☐No ☐N/A	1 hr. rated or sprinkled
Sprinkler System	☐Yes ☐No ☐N/A	NFPA Chpt. 13
Elevator in Facility	☐Yes ☐No ☐N/A	Valid operating permit
Boiler Room in Facility	☐Yes ☐No ☐N/A	1 hr. rated or sprinkled, valid operating permit
Carbon Monoxide Detector	☐Yes ☐No ☐N/A	If any appliances are fueled by fossil fuels.
Note: If you have question	s about fire safety, contact	t your Division of Fire Safety Inspector.